

# Performance Data Sheet

**Models: XB7000** Use Replacement Cartridge XB7000CR

The concentration of the indicated substances in water entering the system was reduced to a concentration less than or equal to the permissible limit for water leaving the system as specified in NSF/ANSI Standard 42 and Standard 53.



System tested and certified by NSF International against NSF/ANSI Standard 42 and Standard 53 for the reduction of substances listed below.

Capacity 25,000 Gallons (94,635 Liters) Contaminant Reduction Determined by NSF testing.

Contaminant Reduction	Average Influent	NSF/ANSI Specified Challenge Concentration	Avg % Reduction	Average Product Water Concentration	Max Permissible Product Water Concentration	NSF Reduction Requirements	NSF Test Report
Chlorine Taste and Odor	2.0 mg/L	2.0 mg/L ± 10%	96%	0.08 mg/L	N/A	≥ 50%	J-00018154
Nominal Particulate Class I, ≥0.5 to < 1.0 µm	3,833,333 pts/mL	At least 10,000 particles/mL	99.4%	19,883 pts/mL	N/A	≥85%	J-00047325
Cyst*	132,750 cysts/L	Minimum 50,000 cysts/L	99.99%	1 cyst/L	N/A	≥99.95%	516513-05

\* Based on the use of *Cryptosporidium parvum* oocysts

Application Guidelines/Water Supply Parameters	
Service Flow	2.1 gpm (7.95 lpm)
Water Supply	Potable Water
Water Pressure	30 -125 psi (172 – 862 kPa)
Water Temperature	40° F - 100° F (4.4° C - 38° C)

It is essential that the manufacturer's recommended installation, maintenance and filter replacement requirements be carried out for the product to perform as advertised. See Installation Manual for Warranty information.

**Note:** While the testing was performed under standard laboratory conditions, actual performance may vary.

Replacement Cartridge: XB7000CR. For estimated costs of replacement elements please call 1-888-836-2006 or visit our website at [www.betterwaters.com](http://www.betterwaters.com)

**WARNING**

**To reduce the risk associated with ingestion of contaminants:**

- **Do not use with water that is microbiologically unsafe or of unknown quality without adequate disinfection before and after the system. Systems certified for cyst reduction may be used on disinfected water that may contain filterable cysts.**

EPA Establishment Number 070595-CT-001

**CAUTION**

**To reduce the risk associated with property damage due to water leakage:**

- **Read and follow** Use Instructions before installation and use of this system.
- Installation and use **MUST** comply with all state and local plumbing codes.
- **Do not** install if water pressure exceeds 125 psi (862 kPa). If your water pressure exceeds 80 psi, you **must** install a pressure limiting valve. Contact a plumbing professional if you are uncertain how to check your water pressure.
- **Do not** install where water hammer conditions may occur. If water hammer conditions exist you **must** install a water hammer arrester. Contact a plumbing professional if you uncertain how to check for this condition.
- **Do not** install on hot water supply lines. The maximum operating water temperature of this filter system is 100° F (38° C).
- **Protect filter from freezing.** Drain filter when temperatures drop below 40°F (4.4°C).
- The disposable filter cartridge **must** be replaced every **12** months, at the rated capacity or if a noticeable reduction in flow rate occurs.

Manufactured for Better Waters by:

Parts and service available from:

NSF is a trademark of NSF International.  
INSTR7117 0810

3M Purification Inc.  
400 Research Parkway  
Meriden, Ct 06450

Better Waters  
P.O. Box 8545  
JAF Station  
New York, NY 10116-8545  
Toll Free: 1-888-836-2006  
Worldwide: 212-366-6700  
[www.betterwaters.com](http://www.betterwaters.com)